

$h = 2.8m$
 $AV \approx 2 \times 18 \times 2.8 = 100.8$ $AF = 370m^2$ $AL = 2 \times 370 + 2 \times 18 \times 4 + 2 \times 21 \times 4$
figure with shaft $= 1068$






Figure 1 Location of Large Compartment Fire Test

Figure 2 Atmosphere Thermocouple Locations - Large Compartment Fire Test



Section A



Section B




Figure 3 Location of Thermocouples
from ceiling - Elevation

Figure 4 Location of cut-outs in concrete slab







Figure 4 Location of cut-outs in concrete slab





cut-out no.	a (mm)	b (mm)
1	31.5	63
2	35	70
3	21	42
4	27.5	55
5	35	70
6	27.5	55

Figure 5 Concrete Slab Thermocouple Positions



cut-out no.	a (mm)	b (mm)
1	31.5	63
2	35	70
3	21	42
4	27.5	55
5	35	70
6	27.5	55

Figure 5 Concrete Slab Thermocouple Positions

Figure 6 Column Identification - Large Compartment Fire Test






Figure 7 Cross-sectional Thermocouple Locations Column C5 (B4)

Figure 8 Cross-sectional Thermocouple Locations Columns C6 and C7 (B3&B2)





Figure 8 Cross-sectional Thermocouple Locations Columns C6 and C7 (B3&B2)






Figure 9 Cross-sectional Thermocouple Locations Columns C8 and C13 (B1&A1)










Figure 10 Cross-sectional thermocouple locations column C9 (A4)




Note: All thermocouples 25mm in from edge of flange , o/s = outside, i/s = inside

Figure 11 Position of Thermocouples associated with weldable strain gauges

Note: All thermocouples on outside of flange 25mm in from edge

Figure 1.2 Additional Thermocouples at top of columns (T1-T8)







Figure 13 Secondary Beam Identification

Figure 14 Thermocouple Locations for Secondary Beams B1, B6, B8, B9, B10, B12 and B16 looking East







Figure 15 Primary Beam Identification

Figure 16 Thermocouple locations for primary beams B21-25 looking North







Figure 17 Position of Thermocouples Opposite the Compartment


- 1 = central walkway height above centre of compartment
49m from G.L.
- 2 = 6 m. below previous = 43m. from G.L.
- 3 = 6m. below previous = 37m. from G.L.

Assumes Ambient-50°C



Scale: 1-500

Figure 19 Additional Thermocouples - Beam B4 between Gridlines B and C







Figure 20 Additional Thermocouples beam B4

* C11 not used




If gauge is located on inside of flange then this will be denoted by a ' alongside cable reference eg. 231

F denotes floor eg. F1 is floor 1, C denotes column eg. C1 is column 1

Figure 21 Column Strain Gauge Layout

Figure 22 Cross-sectional strain gauge locations







Figure 23 Reinforcement gauge layout 3rd floor

Figure 24 Concrete Slab Gauge Layout 3rd Floor







Figure 25 Location of Displacement Transducers 1-24

Figure 26 Location of Displacement Transducers 25-50







Figure 27 Location of Displacement Transducers on 4th floor

Target Positions For 3D-Laser Survey System Monitoring of West Wall Movement During the Half-Floor Fire Test at Cardington, 2/4/96



NOTES: NOT TO SCALE
TARGET NUMBERS 1,2,3,64,65 NOT USED

Figure 28

DRAWN BY ANDRÉ BOUGARD
STRUCTURAL PERFORMANCE DIVISION
BUILDING RESEARCH ESTABLISHMENT




Figure 29 Crib Layout Large Compartment Fire Test

Max. Heat Output = 1.7 mW
 Time to peak = 20 mins.
 Steady burning = 40 mins.
 Total mass = 425 kg
 Total no. of sticks = 340




Fig 30 Crib Dimensions, Large Compartment Fire Test